# **HM10 SERIES EV charger**



# User Manual

UM230603.A5A4

# About this User Manual

Read carefully before installation, maintenance and operation!

- ▶ Failure to read this manual carefully may lead to improper operation.
- ▶ Failure to follow the safety notes may lead to a danger of death, injury and damage to the device, supplier cannot accept any liability for claims resulting from this.

Thank you very much to use our AC EV Charging Station.

This manual describes the installation, use and maintenance of AC EV Charging station. This manual is intended for installation and maintenance personnel.

| Article                             | Model Number |
|-------------------------------------|--------------|
| 1-phase, 3.5kW, with charging cable | HM10116      |
| 1-phase, 7kW, with charging cable   | HM10132      |
| 3-phase, 11kW, with charging cable  | HM10316      |
| 3-phase, 22kW, with charging cable  | HM10332      |
| 1-phase,3.5kW, with case B socket   | HM10116B     |
| 1-phase, 7kW, with case B socket    | HM10132B     |
| 3-phase, 11kW, with case B socket   | HM10316B     |
| 3-phase, 22kW, with case B socket   | HM10332B     |

The text and illustrations in this user manual are general explanations of these type of equipment, and the actual product may be inconsistent with this manual in detail.

All rights reserved.

- 1 -

# **CONTENTS**

| 1. | ABBREVIA        | TIONS                  | 4  |
|----|-----------------|------------------------|----|
| 2. | SAFETY NO       | OTES                   | 5  |
|    |                 | signs used             |    |
|    | ,               | nment                  |    |
|    |                 | tion                   |    |
|    |                 | tion                   |    |
|    |                 | nance                  |    |
| 3. | STANDARI        | DS COMPLIANCE          | 9  |
|    | 3.1. Chargir    | ng mode                | 9  |
|    | 3.2. Chargir    | ng connection          | 9  |
|    | 3.3. Chargir    | ng interface           | 10 |
| 4. | PRODUCT         | INFORMATION            | 11 |
|    | 4.1. Genera     | il                     | 11 |
|    | 4.2. Model      | number definition      | 12 |
|    | 4.3. Specific   | cations                | 12 |
|    | 4.3.1. Electric | al specifications      | 12 |
|    | 4.3.2.          | Functional description | 13 |
|    | 4.3.3.          | Ambient conditions     | 14 |
|    | 4.3.4.          | Mechanical parameters  | 14 |
|    | 4.4. Namep      | olate                  | 14 |
| 5. | INSTALLA        | TION                   | 16 |
|    | 5.1. Unpack     | king                   | 16 |
|    | 5.1.1. Packing  | g list                 | 16 |
|    | 5.1.2. Inspect  | tion & confirm         | 16 |
|    | 5.2. Prepare    | e                      | 17 |
|    | 5.3. Power      | supply system          | 18 |
|    | 5.4. Installa   | ition steps            | 19 |

|     | 5.5. Empty     | socket                 | 23 |
|-----|----------------|------------------------|----|
| 6.  | OPERATIO       | N                      | 24 |
|     | 6.1. Power     | on                     | 24 |
|     | 6.2. Human     | n-Machine Interface    | 24 |
|     | 6.2.1. Overvie | ew                     | 24 |
|     | 6.2.2.         | LCD indicators         | 24 |
|     | 6.2.3.         | RFID reader            | 26 |
|     | 6.2.4.         | LED indicators         | 26 |
|     | 6.2.5 Chargii  | ng control button      | 27 |
|     | 6.3. Configu   | ure parameters         | 27 |
|     | 6.4. Start Cl  | harging                | 29 |
|     | 6.5. Norma     | ılly stop charging     | 30 |
|     | 6.6. Abnorr    | mally stop charging    | 31 |
| 7.  | FAULT HA       | NDLING AND MAINTENANCE | 32 |
|     | 7.1. Fault H   | landling               | 32 |
|     | 7.2. Mainte    | nance                  | 34 |
| WA  | RRANTY AC      | GREEMENT               | 35 |
| DEC | CLARATION      | I OF CONFORMITY(DOC)   | 36 |
| CO  | MPLIANCE :     | STATEMENT OF WEEE      | 37 |

# 1. ABBREVIATIONS

| S/N | Abbreviations | Description                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |  |  |
|-----|---------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| 1   | IEC           | International Electrotechnical Commission                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |  |
| 2   | EV            | Electrical Vehicle, this can be BEV (battery EV) or PHEV (plug-in hybrid EV)                                                                                                                                                                                                                                                                                                                                                                                                                                              |  |  |
| 3   | EVSE          | Electric Vehicle Supply Equipment [IEC61851-1]                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |  |  |
| 4   | OBC           | On-board charger (of an EV)                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               |  |  |
| 5   | LCD           | Liquid Crystal Display                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |  |  |
| 6   | LED           | Light-emitting Diode                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      |  |  |
| 7   | RFID          | Radio Frequency Identification                                                                                                                                                                                                                                                                                                                                                                                                                                                                                            |  |  |
| 8   | CMS           | Central Management System                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |  |
| 9   | OCPP          | Open Charge Point Protocol                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |  |  |
| 10  | IP            | Ingress Protection                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |  |  |
| 11  | HMI           | Human-Machine Interface                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   |  |  |
| 12  | RCMU          | Residual Current Monitoring Unit                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |  |  |
| 13  | МСВ           | Miniature Circuit Breaker                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 |  |  |
| 14  | TN            | "T" — indicates the connection between earth and the power supply is direct connection of a point with earth (French: Terre).  "N" — the earth connection is supplied by the electricity supply network, either separately to the neutral conductor (TN-S), combined with the neutral conductor (TN-C), or both (TN-C-S).  TN-S system  TN-C-S system  230/400VAC  TN-C-S system 230/400VAC  TN-C-S system 230/400VAC  11 12 13 N PEN 13 N PEN 13 N PEN 14 15 15 N PEN 15 16 17 17 18 18 18 18 18 18 18 18 18 18 18 18 18 |  |  |
| 15  | PE            | Protective Earth. The conductor that connects the exposed metallic parts of the consumer's electrical installation                                                                                                                                                                                                                                                                                                                                                                                                        |  |  |
| 16  | PEN           | PEN line is to accurately and well ground the original neutral line, and connect the shell of the equipment to be protected to the PEN line                                                                                                                                                                                                                                                                                                                                                                               |  |  |

# 2. SAFETY NOTES

## 2.1. Safety signs used

The following warning signs, mandatory signs and information signs are used in this manual, on and in the AC EV Charging station.



CAUTION: Warning of electrical hazards.

This sign is intended to alert the user that severe personal injury or substantial property damage can result if the device is not operated as requested.



**ATTENTION**: Warning of a danger spot or dangerous situation.

This sign is intended to alert the user that minor personal injury or material damage can result, if the device is not operated as requested.



CAUTION: Do not touch by hands in case of ESD.

Indicates the possible consequences of touching electrostatically sensitive components.



CAUTION: Warning of combustion.



No access for unauthorized persons.



No access for persons wearing pacemakers.



Use protective footwear.



Must wear a safety helmet.



Indicates important texts, notes or tips.



Indicates recycling information.



Indicates assemblies or parts that must be disposed of properly.

Do not dispose of them in the household waste.

#### 2.2. Environment



- EV Charging station should be installed on the incombustible such as concrete; otherwise, hazardous fire may result.
- EV Charging station should not be installed in the area that contains explosive gas; otherwise, hazardous blast may result.
- Leave no inflammable or explosive substances near the EV Charging station; otherwise, hazardous blast may result.



- EV Charging station should be installed in a place with no conductive dust and insulation-destructive gas or vapor.
- EV Charging station should be installed in a place with no violent vibration and impact; for good ventilation, mount the charging station vertically.
- The installation foundation shall be higher than the ground level, and drainage ditch shall be set around the EV Charging station, otherwise the equipment may be damaged.

#### 2.3. Installation





Safety protection must be done when installing the EV Charging station.



- Installation and wiring should be done by personnel with professional qualification, otherwise, hazardous electric shock may result.
- Make sure input power supply is entirely disconnected before wiring; otherwise, hazardous electric shock may result.
- PE terminal of the EV Charging station must be grounded securely; otherwise, hazardous electric shock may result.
- The lead nose of the charging station must be securely attached or there is a risk of damaging the equipment.



- Main loop terminal of the EV Charging station should be firmly connected with the wiring ends; otherwise, damage to property may result.
- Bare parts of wiring ends of electrical cables must be wrapped with insulating tape; otherwise, hazardous fire and property loss may result.

## 2.4. Operation



- Strictly forbidden for minors or persons of restricted capacity to approach the charging station to avoid injury.
- ▶ Forced charging is strictly forbidden when the electric vehicle or charging station fails.
- ▷ It is strictly prohibited to use the charging station when the charging adapter or charging cables are defective, cracked, worn, broken or the charging cables is



exposed. If you find any, please contact the supplier in time.



Do not charge in rainy and thunderous weather.

## 2.5. Maintenance





Personnel must always use protective footwear when maintenance work.

Caution ESD to avoid damaging electronic devices, especially to protect microchips on PCBA.



Accessory replacement must be done by qualified personnel, thrums or metals are prohibited to be left in the controller; otherwise, hazardous blast and fire may result.



- After replacing main PCBA, parameters must be adjusted and matched before operation; otherwise, property loss may result.
- ▷ It is recommended that routine safety inspection visits to charging station be conducted at least once a week.

## 3. STANDARDS COMPLIANCE

## 3.1. Charging mode

■ Conformed to EN IEC 61851-1:2019



Charging mode:

method for connection of an EV to the supply network to supply energy to the vehicle

■ The Charging mode of HM10 series product is Mode 3



Mode 3 is a method for the connection of an EV to an AC EV supply equipment permanently connected to an AC supply network, with a control pilot function that extends from the AC EV supply equipment to the EV.

## 3.2. Charging connection

■ According to EN IEC 61851-1:2019, HM10 series products meet the Case C connection.



Case C:

Connection of an EV to a supply network utilizing a cable and vehicle connector permanently attached to the EV charging station.




Fig. 3-1 Schematic diagram of CASE C connection

## 3.3. Charging interface

■ The charging connector of HM10 series products meet IEC 62196-2, Type 2 plug (with charging cable).




Fig. 3-3 Schematic diagram of Type 2 socket on M3B series products

Fig. 3-2 Type 2 plug on HM10 series products

HM10 series products provide a Type 2 female plug with charging cable, it only charging an EV with a
Type 2 vehicle inlet.

# 4. PRODUCT INFORMATION

## 4.1. General

Welcome to use AC EV Charging station produced by our company.

■ The shape & dimensions of AC EV charging station shown as Fig. 4-1.




Fig. 4-1 The shape & dimensions of HM10 series

■ The block diagram of AC EV charging station is shown as Fig. 4-2.




Fig. 4-2 Block diagram of products

It is widely used in all kinds of household electric vehicle charging, as well as various charging stations,

parking lots, community garages and public electric vehicle charging places.

## 4.2. Model number definition

The model number definition of charging station follows the rules as shown in Fig. 4-3.




Fig. 4-3 Model number definition

## 4.3. Specifications

## 4.3.1. Electrical specifications

| Model Number                   | HM10116                                                                                                    | HM10132                           | HM10116                           | HM10132                           |
|--------------------------------|------------------------------------------------------------------------------------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|
| Rated Voltage                  | 230V, 50/60Hz                                                                                              |                                   | 400V, 50/60Hz                     |                                   |
| Rated Current                  | 16A                                                                                                        | 32A                               | 16A                               | 32A                               |
| Rated Power                    | 3.5kW (@230V, 1-<br>phase)                                                                                 | 7kW (@230V, 1-<br>phase)          | 11kW (@400V, 3-<br>phase)         | 22kW (@400V, 3-<br>phase)         |
| Recommended power supply cable | 3×4mm², copper                                                                                             | 3×6mm², copper                    | 5×4mm², copper                    | 5×6mm², copper                    |
| MCB<br>recommended             | Dedicated circuit,<br>20A, 2-Pole                                                                          | Dedicated circuit,<br>40A, 2-Pole | Dedicated circuit,<br>20A, 4-Pole | Dedicated circuit,<br>40A, 4-Pole |
| Input Terminals                | L / N/ PE L1/ L2/L3 N/ PE                                                                                  |                                   | 3 N/ PE                           |                                   |
| Charging interface             | IEC 62196-2, Type 2, 1-phase / 3- phase plug with 5m cable  Note: That cord extension sets are not be used |                                   |                                   |                                   |

| Model Number                   | HM10116B                                             | HM10132B                          | HM10316B                          | HM10332B                          |
|--------------------------------|------------------------------------------------------|-----------------------------------|-----------------------------------|-----------------------------------|
| Rated Voltage                  | 230V, 50/60Hz                                        |                                   | 400V, 50/60Hz                     |                                   |
| Rated Current                  | 16A                                                  | 32A                               | 16A                               | 32A                               |
| Rated Power                    | 3.5kW (@230V, 1-<br>phase)                           | 7kW (@230V, 1-<br>phase)          | 11kW (@400V, 3-<br>phase)         | 22kW (@400V, 3-<br>phase)         |
| Recommended power supply cable | 3×4mm²,copper                                        | 3×6mm²,copper                     | 5×4mm²,copper                     | 5×6mm²,copper                     |
| MCB<br>recommended             | Dedicated circuit,<br>20A, 2-Pole                    | Dedicated circuit,<br>40A, 2-Pole | Dedicated circuit,<br>20A, 4-Pole | Dedicated circuit,<br>40A, 4-Pole |
| Input Terminals                | nput Terminals L/ N/ PE                              |                                   | L1/L2/L3                          | 3/ N/ PE                          |
| Charging interface             | IEC 62196-2, Type 2, 1-phase/3-phase charging socket |                                   |                                   |                                   |

## 4.3.2. Functional description

| Model series         | HM10 series                                                                                                                                  |
|----------------------|----------------------------------------------------------------------------------------------------------------------------------------------|
| Charging Mode        | Mode 3                                                                                                                                       |
| Charging Control     | Remote: "APP-controlled"  Local: "Button-controlled" or "Card-controlled"                                                                    |
| Indicator Lights     | Multi-color atmosphere lights                                                                                                                |
| Networking interface | WiFi (2.4GHz / 5G Hz), and support OCPP 1.6J Protocol (Optional)                                                                             |
| Safety Protection    | Surge protection, over temperature, over/under voltage, over current, leakage fault, ground protection for TN system (TN-C, TN-S and TN-C-S) |
| RCMU Built-in        | Yes, Type A + 6 RCMU (meet IEC 62955) built-in                                                                                               |

## 4.3.3. Ambient conditions

| Model series          | HM10 series                                                        |
|-----------------------|--------------------------------------------------------------------|
| Altitude              | ≤ 2000m                                                            |
| Storage temperature   | -40 ~ 70°C                                                         |
| Operation temperature | -30 ~ 50°C                                                         |
| Relative humidity     | ≤ 95%RH, no water droplet condensation                             |
| Vibration             | < 0.5G, no acute vibration and impaction                           |
| Installation location | Indoor or outdoor, good ventilation, no flammable, explosive gases |

## 4.3.4. Mechanical parameters

| Model series     | HM10 series                                               |
|------------------|-----------------------------------------------------------|
| Mounting         | Wall-mounted or pole-mounted (mounting pole is optional)  |
| Net Weight       | ≤ 7kg                                                     |
| Dimension        | H×W×D = 398mm ×210mm × 145mm                              |
| Color & Material | Front cover: space gray, PC+ASA; Back cover: Black PC+ASA |
| IP Code          | Case C: IP65                                              |
| - Code           | Case B: IP54                                              |
| IK Code          | IK10                                                      |

## 4.4. Nameplate

On the wallbox shell, there is a nameplate identifying the model and specification of the charging station, the content is shown as Fig. 4-4.

# **AC EV Charging station**

Model No.: HM10332 Input Phase: 3P + N + PE

Rated Input: 400VAC, 50/60Hz, 32A Rated Output: 400VAC, 50/60Hz, 32A

Rated Power: 22kW

Connector: IEC 62196-2, Type 2 Location: Indoor / Outdoor

IP Code: IP 65 OTR: -30 ~ 50°C





- This equipment should be reliably grounded before use.
   Installation, wiring and maintenance should be done by personnel with professional qualification.
- 3. Do not expose to flammable gas.
  - 4. Failure to read user manual carefully before use may lead to improper operation.

#### Sichuan WeiYu Electric Co., Ltd.

Address: The Northeast Corner of Crossing of Minshan Road and Tumenjiang Road, Economic Development Zone, Deyang, Sichuan, P.R. CHINA.

Fig. 4-4 The location and content of the nameplate

## 5. INSTALLATION

## 5.1. Unpacking

## 5.1.1. Packing list

| Package                                                           | Quantity |
|-------------------------------------------------------------------|----------|
| AC EV Charging Station                                            | 1 pc     |
| Empty socket                                                      | 1 pc     |
| RFID card                                                         | 2 pcs    |
| Wall-mounting accessories (including A+B+C+D+E as Fig. 5-1 shown) | 1 set    |
| User manual                                                       | 1 pc     |
| Quality certificate                                               | 1 pc     |




Fig. 5-1 Wall-mounting accessories

## 5.1.2. Inspection & confirm

When unpacking, please carefully confirm the following points:

- Whether the accessories are missing according to the packing list.
- Whether there is any damage during transportation.
- Whether the model and specification of the machine's nameplate are consistent with the order requirements.



- ▷ If any damage or missing parts are found, please do not start the machine and contact the supplier as soon as possible.
- ▶ Please keep the packing box and packing materials 1 month for future handling.



> The paper packaging is recyclable.

## 5.2. Prepare

When transporting or moving the charging station, pay attention to the following points to ensure product safety:



- ▷ This product is electrical equipment. It should be handled with care to avoid violent vibration and impact.
- ▷ The charging station shall not be transported by dragging the charging connector and the charging cable.
- In order to ensure the long-term stable operation of the product, it is recommended to avoid installing charging stations in extreme weather as far as possible, especially low or high ambient temperature may affect the installation effect due to thermal expansion and cold contraction.
- The electrical power supply cable must be prepared. Please refer to Clause 4.3.1 to select the power cable.
- Space requirement: When the charging station is fixed on the wall, the minimum space requirements are shown in Fig. 5-2.




Fig. 5-2 Minimum space requirements for wall mounting

- It is suggested that the charging station should be installed in a place with good ventilation, no direct sunlight and shelter from wind and rain. In order to ensure good ventilation condition, you should mount the charging station vertically and leave enough space.
- Tools for installation

Prepare the following tools at least before installing the AC EV charging station.

| Sr No. | Tools' Name           | Schematic Picture | Main Uses                                               |
|--------|-----------------------|-------------------|---------------------------------------------------------|
| 1      | Multimeter            |                   | Check the electrical connection and measure the voltage |
| 2      | Electric Impact drill |                   | Drill fixing holes in the wall                          |
| 3      | Wrench                | ~                 | Fastening bolt                                          |
| 4      | Diagonal plier        | 20/               | Cut the cable                                           |
| 5      | Wire stripper         | 2                 | Peeling cables                                          |
| 6      | Crimping plier        |                   | Pressed cable terminal                                  |
| 7      | Cross screwdriver     | -                 | Fastening screw                                         |

# 5.3. Power supply system

HM10 series products are suitable for installation in TN power supply system.

a) TN-S power supply system wiring mode




Fig. 5-3 HM10 work in TN-S system

#### b) TN-C power supply system wiring mode

Earth rod should be installed as far as possible to ensure that household electrical equipment can be effectively protected zero connection. The Fig.5-4 shows the TN-C power supply system with earth rod.




Fig. 5-4 HM10 work in TN-C system with earth rod

In TN-C, for local earth rod where there is no condition to install, a series of circuits are set inside HM10 to protect safety. Even if leakage fault occurs when PEN is disconnected or three-phase voltage is unbalanced, HM10 can quickly interrupt charging and protect the personal safety of users.

c) TN-C-S power supply system wiring mode

The connection method is the same as that of TN-S power supply system.

## 5.4. Installation steps

Install the Charging station on the wall follow the steps as below.

Step 1: Drilling




Fig. 5-5 Wall-mounting accessories-E

Drill 3 holes with diameter of 6mm and depth of at least 50mm on the wall using wall-mounting accessories-E.

## ■ Step 2: Fixed the wallbox

As shown in Figure 5-6, use Mounting Accessory-A and Mounting Accessory-B to install Mounting Accessory-C on the wall;




Fig. 5-6 Fixed the Wall-mounting accessories-D

As shown in Fig. 5-7, Use tools to open decorative covers and sealing covers.




Fig. 5-7 Open the lid

As shown in Figure 5-8,

Step 1: install the wall box on the wall in the direction of the arrow;

Step 2: use the installation accessories-B and the installation accessories-C to fix the wall box.





Fig. 5-8 Install the Wall Box

■ Step3: Wiring



As shown in Fig. 5-9,

- 1. Pass the prepared power cable through the rubber grommet [A];
- 2. Remove the 12mm insulation layer on the wire;
- According to the label number on the terminal, insert the wire into the corresponding terminal, and tighten the screws to ensure that each reliable connection between wires and terminals.

Note: It is recommended to install a miniature circuit breaker on the input line outside the charging station.

Step4: Close the lid




Fig. 5-10 Close the lid

As shown in Fig. 5-10,

- Install the sealing cover on the wall box with the removed screws (ten screws in total). Please
  ensure that the installation is firm after installation:
- Install the decorative cover on the wall box. The decorative cover is installed by means of snaps, please ensure that the installation is firm.

## 5.5. Empty socket

HM10 Case C series AC EV charging station config a type 2 charging connector. When the charging station is in standby state, please plug the charging connector in the empty connector socket in order to protect the charging connector. Please use expansion screws to fix this empty socket at a suitable position beside the charging station.




Fig. 5-9 Empty socket

## 6. OPERATION


#### 6.1. Power on

After the charging station has been installed and confirmed, switch on the power supply. The light and screen lights up and the charging station switches to standby state.

#### 6.2. Human-Machine Interface

#### 6.2.1. Overview

As shown in Fig. 6-1, HM10 series product is configured with multiple human-machine interfaces.



- [A] Screen display area: A screen used to display system status
- [B] Swipe card area: Swipe the RFID card to charging
- [C] Indicator lights: It is used to show indicate system status
- [D] Charging control button: Start or stop charging by press for Button-controlled charging

Fig. 6-1 HMI of AC EV Charging Station

#### 6.2.2. LCD indicators

The screen is used to display the running status of charging stations, which is convenient for users to know the real-time situation of charging stations. In the status bar of the upper part, the accumulated charging electric energy and CP status of Bluetooth WIFI are displayed. The pile number and fault code are listed on the status bar in the following section

#### Standby state





### ② Connection status






#### 3 Charging status






#### System failure



#### System upgrade



#### Scan the QR code binding



#### 6.2.3. RFID reader

In general, the charging station is equipped with RFID card reader as standard, and the charging process can be started and stopped by using the RFID card (shown as Fig. 6-2) configured with the host. The special customized card swiping function is not separately described here.




Fig. 6-2 RFID card

#### 6.2.4. LED indicators

The LED indicators on the panel are used to indicate the status of the charging station and the various combinations of indicators are described as below.

| No. | Indicator<br>Color | LED Status        | Connotation                                                                                                                              |
|-----|--------------------|-------------------|------------------------------------------------------------------------------------------------------------------------------------------|
| 1   | Green              | ON                | Standby status                                                                                                                           |
|     |                    | Breath            | Connecting to the server                                                                                                                 |
| 2   | Blue               | ON                | connected to an EV                                                                                                                       |
|     |                    | Twinkle           | Start charging state                                                                                                                     |
|     |                    | Breath            | Charging status                                                                                                                          |
| 3   | Purple             | Twinkle           | Charge end                                                                                                                               |
| 4   | Red Yellow         | Yellow ON/Red Off | Ground fault                                                                                                                             |
|     |                    | Twinkle           | System failure: Blinking red Indicates the high<br>level of the fault code. Blinking yellow indicates<br>the low level of the fault code |

#### 6.2.5 Charging control button

You can press the button to control charging, when HM10 work in button-controlled mode.

#### Mode 1:

- Start charging: plug the charging connector into EV socket, press button to start charging.
- Stop charging: press button again will end the charging, when EV is in charging.

#### Mode 2:

- Start charging: plug the charging connector into EV socket, keep the button pressed to start charging.
- Stop charging: release the button up will end the charging, when EV is in charging.

# 6.3. Configure parameters

Taking the configuration of charging station parameters by laptop as an example, it is introduced as follows (the method of setting parameters by mobile phone is similar and will not be repeated):

■ Step 1: connect to WiFi hotspot

Keep your laptop in a state where it can connect to WiFi hotspots. Power on the charger. Find a hotspot with name "EVSE-XXXXXXXX" (XXXXXXXX are 8 numbers, for example "EVSE-82555964"), and connect it, don't need a password. (If you don't find a hotspot with name "EVSE-XXXXXXXX", please restart the power supply of charger).



Fig. 6-3 Connect the WiFi in Windows OS

#### Step 2: login to setting

Open a web browser on your laptop, preferably using Google Chrome or Microsoft Edge, and fill the IP address "192.168.4.1" in the address bar of the browser, press the enter key to access the webpage of EVSE CONFIGURATION LOGIN shown in Fig. 6-5 (Note: Microsoft IE browser cannot access).




Fig. 6-4 Login of EVSE CONFIGURATION

#### ■ Step 3: Config your EV Charging station

Fill the default password "12345678" to enter the page shown in Fig. 6-5. Please change a new login password at the first-time login this webpage. As shown in Fig. 6-6, set the parameters on this webpage.




Fig. 6-5 Set parameters to config the EV charging station

After setting, click the "SAVE" button to save the settings, click the "SAVE & RESTART" button to restart charging station for settings take effect. Enter your WiFi name and password in the page. After it takes effect, the charging station can access Internet via your WiFi.

## 6.4. Start Charging

- a) Park your EV into place, turn off, and put the EV under braking.
- b) Pick off the charging connector form empty socket of EV charging station.
- c) As shown in Fig.6-6, plug the charging connector into the AC charging socket of the EV.

d) For the charging control mode of "Button-controlled", press the button after EV connector plug in, the charging will start automatically.



Fig. 6-6 Plug into EV socket

For the charging control mode of "Card-controlled" or "APP-controlled", you can control charging
process by swipe RFID card or APP after charging connector plug in.



▷ If you want to scan QR code on the screen to start charging, please download and install the WE E-Charge APP on your smart phone.



WE E-Charge

▷ For Android phone, search "WE E-Charge" in Google Play Store or scan the QR code on the right to install APP.





▷ For iPhone, search "WE E-Charge" in APP Store or scan the QR code on the right to install APP.





> The user manual of APP please refer to the FAQ of APP.

# 6.5. Normally stop charging

- a) The charging station will automatically stop when the electric vehicle is fully charged.
- For the charging control mode of "Button-controlled", you can stop charging by press button again, when EV is in charging.
- For the charging control mode of "Card-controlled", you can stop charging by swipe your RFID card again, when EV is in charging.
- For the charging control mode of "APP-controlled", click the stop button on your APP, the charging will stop.

 When the charging is end, please unplug the charging connector and plug back to the empty socket of charging station.

# 6.6. Abnormally stop charging

- a) Forced fault stop: A fault stop initiated by the onboard charger of vehicle.
- b) Automatic fault stop: A fault stop initiated by the charging station.

# 7. FAULT HANDLING AND MAINTENANCE

# 7.1. Fault Handling

The charging station is automatically protected in the event of the fault. The fault information and handling methods are as follows.

| LED indicator                  | Fault code                                 | Handling method                                                                                                                                                                                                                                                                                                 |
|--------------------------------|--------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| LED are not on                 | -                                          | <ul> <li>Check whether the power supply and distribution are normal;</li> <li>Check whether the branch breaker is tripped, and close the breaker after troubleshooting;</li> <li>Check whether the connection is correct, if the cable comes off, should be properly connected to tighten the cable.</li> </ul> |
| ● LED flash:  Red×1+Yellow×1   | Fault code 11:  CP voltage anomaly         | Check the connection of charging connector and EV socket.      Disconnect and reconnect the charging connector.                                                                                                                                                                                                 |
| ● LED flash:  Red×1+Yellow×3   | Fault code 13: Undervoltage input          | Check whether the input cable is reliably connected.      Check whether the input voltage is abnormal.                                                                                                                                                                                                          |
| • LED flash:  Red×1+Yellow×4   | Fault code 14:  Overvoltage input          | Check whether the input cable is connected correctly.      Check whether the input voltage is abnormal.                                                                                                                                                                                                         |
| ● LED flash:<br>Red×1+Yellow×5 | Fault code 15: Over-temperature protection | Check whether the charging station is covered or installed in a high temperature environment.                                                                                                                                                                                                                   |

| LED indicator    | Fault code         | Handling method                                         |
|------------------|--------------------|---------------------------------------------------------|
| ● LED flash:     | Fault code 17:     | • Check whether the charging connector and its cable    |
| Red×1+Yellow×7   | Leakage protection | are damaged or wet.                                     |
|                  |                    | Recover after pulling out the adapter.                  |
| • LED flash:     | Fault code 18:     | Check whether the charging adapter and its cables are   |
| Red×1+Yellow×8   | Output shortage    | damaged or wet.                                         |
|                  |                    |                                                         |
| • LED flash:     | Fault code 19:     | • Check whether the charging connector is correctly     |
| Red×1+Yellow×9   | Output overcurrent | connected.                                              |
|                  |                    | Check whether the OBC is normal.                        |
|                  |                    | Check the set of output current.                        |
| • LED flash:     | Fault code 21:     | Battery of EV is full. Or the charging connector is not |
| Red×2+Yellow×1   | EV response        | properly connected.                                     |
|                  | timeout            | Disconnect and reconnect the charging connector.        |
| • LED flash:     | Fault code 22:     | • This EV does not meet the IEC standards and cannot    |
| Red×2+Yellow×2   | EV not supported   | be charged.                                             |
| ● LED flash:     | Fault code 23:     | The device is damaged and needs to be returned to       |
| Red×2+Yellow×3   | Relay sticking     | the factory for repair.                                 |
| • LED flash:     | Fault code 24:     | The RCD is damaged and needs to be returned to the      |
| Red×2+Yellow×4   | • RCD fault        | factory for repair.                                     |
| • LED always on: | Fault code 25:     | Charging station is not grounded; input power cable     |
| Yellow           | Ground fault       | needs to be checked.                                    |
| • LED flash:     | Fault code 26:     | • The ground cable has leakage current, and the         |
| Red×2+Yellow×6   | Ground leakage     | charging station needs to be restarted                  |
|                  | current            |                                                         |

#### 7.2. Maintenance

To ensure the long-term stable operation of the equipment, please maintain the equipment regularly (usually every month) according to the operating environment.

- a) The equipment is maintained by professionals.
- b) Check whether the equipment is well grounded and safe.
- c) Check whether there are potential safety hazards around the charging station, such as whether there are high temperature, corrosion or inflammable and explosive articles close to the charging station.
- d) Check whether the join point of the input terminal is in good contact and whether there is any abnormality. Check whether other terminal points are loose.

## WARRANTY AGREEMENT

- 1. The scope of warranty refers to the product itself.
- The warranty period is 12 months. During the warranty period, the company will repair
  the product free of charge in case of failure or damage (determined by the company's
  technical personnel) under normal use.
- 3. The starting time of warranty period is the date of product manufacture.
- 4. Even in the warranty period, a certain maintenance fee will be charged in case of the following situations.
  - ① Equipment failure caused by not following the user's manual.
  - 2 Equipment damage caused by fire, flood, abnormal voltage, etc.
  - 3 Equipment damage caused by using the product for abnormal functions.
  - 4 Equipment damage caused by foreign matter entering.
  - (5) Equipment damage caused by other human external factors.
- The service fee shall be calculated according to the actual cost. If there is another contract, the contract shall prevail.
- Please be sure to keep this card and show it to the maintenance personnel during the warranty period.
- 7. If you have any questions, please contact the agent or our company directly.

After sales service center

# **DECLARATION OF CONFORMITY(DOC)**

We, declare that the construction of the device described in the following complies with the relevant stated below

Relevant EC directives: Directive 2014/53/EU on radio equipment and telecommunications terminal equipment (RED Directive 2014/53/EU).

Harmonized EN basic and engineering standards: IEC 61851-21-2, EN 301489-1/-17, EN 300328, EN 300330, EN 61000-3-11/-12.



# **COMPLIANCE STATEMENT OF WEEE**

This product cannot be discarded at will when it is abandoned. It must be collected separately for special treatment.



